

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-1209:185 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** System Sensor, 3825 Ohio Ave., St. Charles IL 60174  
Contact: \*Trish Linhart (630) 377-6674 Fax (630) 377-7245

**DESIGN:** Models 1151EIS, 1100D, 1112/24D ionization smoke detectors. Model 1100D is a 2-wire smoke detector that utilizes a snap-in terminal block for system connection. Model 1112/24D is a 4-wire smoke detector that uses the same terminal block as Model 1100D. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as ionization smoke detectors when used in conjunction with separately listed electrically compatible fire alarm control units and bases.

\*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager